



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 12/29/09

Code 46.3.3-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R317.3.5 Flashing, fasteners in direct contact with treated wood. (NEW SECTION)		Page 66
Proponent Calvin Bolt	Title	
Address 1310 Oriole Dr., Warsaw, IN 46580		Phone 574-269-3507
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Add a new Section 317.3.5 Flashing, Fasteners in direct contact with treated wood. When prohibited by the manufacturer of the chemicals used in the treatment of the wood, aluminum flashing, fasteners and other hardwood shall not be in direct contact with the treated wood.</p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward part of an amendment from the 2005 Indiana Residential Code – R319.3.</p> <p>Aluminum in direct contact with treated wood will corrode.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		